

Exergy analysis of marine waste heat recovery CO2 closed-cycle gas turbine system

Mrzljak, Vedran; Poljak, Igor; Prpić-Oršić, Jasna; Jelić, Maro

Source / Izvornik: **Pomorstvo**, 2020, 34, 309 - 322

Journal article, Published version

Rad u časopisu, Objavljena verzija rada (izdavačev PDF)

<https://doi.org/10.31217/p.34.2.12>

Permanent link / Trajna poveznica: <https://um.nsk.hr/um:nbn:hr:187:278049>

Rights / Prava: [In copyright](#) / [Zaštićeno autorskim pravom](#).

Download date / Datum preuzimanja: **2024-07-11**



Sveučilište u Rijeci, Pomorski fakultet
University of Rijeka, Faculty of Maritime Studies

Repository / Repozitorij:

[Repository of the University of Rijeka, Faculty of Maritime Studies - FMSRI Repository](#)





<https://doi.org/10.31217/p.34.2.12>

Exergy analysis of marine waste heat recovery CO₂ closed-cycle gas turbine system

Vedran Mrzljak¹, Igor Poljak², Jasna Prpić-Oršić¹, Maro Jelić³

¹ University of Rijeka, Faculty of Engineering, Vukovarska 58, 51000 Rijeka, Croatia, e-mail: vedran.mrzljak@riteh.hr; jasna.prpic-orasic@riteh.hr

² Department of Maritime Sciences, University of Zadar, Mihovila Pavlinovića 1, 23000 Zadar, Croatia, e-mail: ipoljak1@unizd.hr

³ Maritime Department, University of Dubrovnik, Ćira Carića 4, 20000 Dubrovnik, Croatia, e-mail: maro.jelic@unidu.hr

ABSTRACT

This paper presents an exergy analysis of marine waste heat recovery CO₂ closed-cycle gas turbine system. Based on the operating parameters obtained in system exploitation, it is performed analysis of each system component individually, as well as analysis of the whole observed system. While observing all heat exchangers it is found that combustion gases-CO₂ heat exchangers have the lowest exergy destructions and the highest exergy efficiencies (higher than 92%). The lowest exergy efficiency of all heat exchangers is detected in Cooler (51.84%). Observed system is composed of two gas turbines and two compressors. The analysis allows detection of dominant mechanical power producer and the dominant mechanical power consumer. It is also found that the turbines from the observed system have much higher exergy efficiencies in comparison to compressors (exergy efficiency of both turbines is higher than 94%, while exergy efficiency of both compressors did not exceed 87%). The whole observed waste heat recovery system has exergy destruction equal to 6270.73 kW, while the exergy efficiency of the whole system is equal to 64.12% at the selected ambient state. Useful mechanical power produced by the whole system and used for electrical generator drive equals 11204.80 kW. The obtained high exergy efficiency of the whole observed system proves its application on-board ships.

ARTICLE INFO

Original scientific paper
Received 1 October 2020
Accepted 9 November 2020

Key words:

Exergy analysis
Marine waste heat recovery
CO₂
Closed-cycle gas turbine

1 Introduction

Marine propulsion systems are nowadays mainly based on the internal combustion diesel engines [1, 2]. Due to its dominancy, scientists and researchers are developing various simulation models which can accurately and precisely track diesel engines operating parameters [3, 4] with an aim to improve its operation. One of the dominant topics in the field of marine internal combustion diesel engines is reducing of its emissions, therefore various systems and methods are developed to satisfy harmful emissions legislative [5-7].

Other marine propulsion systems are significantly less represented in the entire worldwide fleet. As for example, steam propulsion systems are still dominantly represented in the propulsion of LNG (Liquefied Natural Gas) carriers due to the specificity of its operations and transported cargo [8, 9]. However, internal combustion dual-fuel en-

gines each day takes stronger and stronger impact also in LNG carriers propulsion systems, therefore it can be expected that in the near future it will overcome traditional steam propulsion [10, 11].

Gas turbines as a stand-alone devices are rarely used for marine propulsion due to its high price, complex maintenance and other elements which can cause problems in operation or for a ship crew [12]. Gas turbines in marine propulsion can be in the most of the cases found as part of complex propulsion systems which includes several different propulsion elements [13, 14].

The second option for application of the gas turbine in the marine propulsion is using a various upgrades and modifications which increase the efficiency of the whole system [15]. Such upgrades can be performed on the gas turbine [16] or can be installed as an additional component [17, 18]. Many techniques are developed to ensure

application of heat from gas turbine combustion gases for various heating purposes or for additional electrical power production [19-21]. Waste heat recovery systems allow that the whole propulsion plant with a gas turbine as a main propulsion element become a valid competitor to all other propulsion systems [22, 23].

In this paper is performed exergy (second law analysis) of CO₂ closed-cycle gas turbine system which for its operation uses heat from gas turbine combustion gases. This system is a good representation of the widely used techniques for waste heat recovery in additional electrical power production. Based on the obtained operating parameters from exploitation, it is performed calculation of exergy power inputs, outputs, exergy destructions (exergy losses) and exergy efficiencies of each system component and of the whole observed system. By taking into consideration many challenges which will surely occur in practical implementation of the observed system, obtained exergy efficiency of the analyzed waste heat recovery system makes the whole marine propulsion plant (gas turbine + presented CO₂ closed-cycle gas turbine system) a good competitor in comparison to other marine propulsion systems.

2 Description and operating characteristics of the analyzed CO₂ closed-cycle gas turbine system

Scheme of the analyzed waste heat recovery CO₂ closed-cycle gas turbine system is presented in Fig. 1. In Fig. 1 are also presented all the necessary operating points required for the exergy analysis of each system component. Red lines represent the flow of combustion gases, while

light blue dashed lines represent the flow of CO₂, while green dotted lines represent the flow of cooling water in the Cooler.

Analyzed system is composed of several heat exchangers [24, 25], two CO₂ turbines and two CO₂ compressors. The dominant heat exchangers are H1 and H2, in which combustion gases from the main marine gas turbine (and if required from the additional combustion chamber) is used for CO₂ heating before its expansion in T1 and T2. HTR, LTR and IHX are CO₂-CO₂ heat exchangers in which CO₂ of a higher temperature transfer heat to CO₂ of a lower temperature. Two compressors (Compr1 and Compr2) are used for the CO₂ pressure increase. CO₂ cooling is performed in only one component (Cooler) and for the CO₂ cooling purposes is used water (CO₂ transfer heat to cooling water), Fig. 1.

Both turbines and compressors are mounted on the same shaft. A part of cumulative mechanical power produced in both gas turbines is firstly used for the drive of both compressors, while the remaining part of cumulative produced mechanical power (useful power) is used for the electrical generator drive.

In a standard operation, the system did not require any additional fuel consumption – additional combustion chamber is not in operation, both heaters H1 and H2 uses combustion gases produced in a gas turbine only. At the highest loads, when the heat in combustion gases from the gas turbine is not sufficient for required heating in H1 and H2, the additional combustion chamber is applied.

It should be highlighted that in Fig. 1 are not shown CO₂ tanks which are used for the change of CO₂ mass flow




Fig. 1 Scheme of the analyzed waste heat recovery CO₂ closed-cycle gas turbine system along with marked operating points necessary for the exergy analysis




Fig. 2 Scheme for defining exergy analysis parameters of the whole observed waste heat recovery CO₂ closed-cycle gas turbine system

Source: Authors

Table 1 Fluid stream operating parameters of the analyzed waste heat recovery CO₂ closed-cycle gas turbine system [27]

O.P.*	Medium	Temperature (°C)	Pressure (kPa)	Mass flow rate (kg/s)	Specific enthalpy (kJ/kg)	Specific entropy (kJ/kg·K)	Specific exergy (kJ/kg)
1	Air	531.8	104.3	93.8	953.85	4.9019	236.34
2	Air	369.9	104.3	93.8	778.89	4.6594	131.26
3	Air	183.1	104.3	93.8	584.51	4.3027	39.672
4	CO ₂	31.0	7579	127.9	298.80	1.3226	201.33
5	CO ₂	60.6	21190	127.9	323.08	1.3372	221.40
6	CO ₂	60.6	21190	55.7	323.08	1.3372	221.40
7	CO ₂	171.5	21190	55.7	552.37	1.9383	277.47
8	CO ₂	171.5	21190	67.1	552.37	1.9383	277.47
9	CO ₂	303.9	21190	67.1	730.09	2.2896	353.96
10	CO ₂	501.8	21190	67.1	974.51	2.6539	493.42
11	CO ₂	384.1	7579	67.1	849.65	2.6751	362.44
12	CO ₂	227.3	7579	67.1	671.93	2.3664	273.68
13	CO ₂	70.6	7579	67.1	481.64	1.9062	215.99
14	CO ₂	70.6	7579	11.4	481.64	1.9062	215.99
15	CO ₂	171.5	21190	11.4	552.37	1.9383	277.47
16	CO ₂	70.6	7579	55.7	481.64	1.9062	215.99
17	CO ₂	70.6	7579	127.9	481.64	1.9062	215.99
18	CO ₂	60.6	21190	72.2	323.08	1.3372	221.40
19	CO ₂	153.0	21190	72.2	523.05	1.8709	267.56
20	CO ₂	339.9	21190	72.2	774.92	2.3650	377.08
21	CO ₂	235.9	7579	72.2	681.59	2.3855	277.83
22	CO ₂	70.6	7579	72.2	481.64	1.9062	215.99
23	Water	25.0	200	1119.0	105.01	0.3672	0.8095
24	Water	30.0	200	1119.0	125.91	0.4367	1.6781

* O.P. = Operating Point (according to presented operating points in Fig. 1 and Fig. 2)

rate through the observed system and compressors for CO₂ delivery from the observed system to that tanks or in a reverse direction. By changing of CO₂ mass flow rate through the observed system can be performed regulation of produced mechanical power (the same technique is valid for any other closed-cycle gas turbine [26]).

Instead of CO₂, in such system can be used other gases (helium, neon, argon, nitrogen, etc.). However, it should be noted that any other gas in comparison to CO₂ has also different thermodynamic properties and the observed system will not operate with the same operating parameters (with the same temperatures, pressures and mass flow rates) in each operating point from Fig. 1, if any other mentioned gas is used. One of the possibilities in future research of the presented system will surely be investigation of change in operating parameters and system performances when other gases are used.

Exergy analysis of the whole observed waste heat recovery CO₂ closed-cycle gas turbine system is performed by using scheme presented in Fig. 2. Exergy power inputs into the whole observed system are combustion gases from the gas turbine (and from the additional combustion chamber) and cooling water at the Cooler inlet. Exergy power outputs from the whole observed system are combustion gases at the outlet of the observed system (after performing both heat transfers in H1 and H2, Fig. 1) as well as cooling water at the Cooler outlet and useful produced mechanical power. Those elements are sufficient for the exergy analysis of the whole observed system.

3 Operating parameters required for the CO₂ closed-cycle gas turbine system exergy analysis

For the exergy analysis of the whole observed waste heat recovery CO₂ closed-cycle gas turbine system as well as for the exergy analysis of each its component are required pressures, temperatures and mass flow rates in each operating point from Fig. 1 and Fig. 2. These operating parameters are found in [27] and presented in Table 1.

Specific enthalpies and specific entropies of each fluid stream from Table 1 are calculated by using NIST-REFPROP 9.0 software [28] from known pressures and temperatures.

Specific exergies of each fluid stream are calculated by using Eq. 4. For the specific exergies calculation must be defined the ambient base (dead) state for which the calculations are performed [29, 30]. Ambient base (dead) state for the exergy analysis can be selected provisionally [31, 32] and is related to the pressure and temperature of the ambient in which system or a control volume operates. In this paper, with the ambient pressure of 1 bar (100 kPa) and the ambient temperature of 15 °C (288.15 K) is defined base (dead) state for the exergy analysis.

With an aim to simplify calculations, in this paper in operating points 1, 2 and 3 are used properties of pure air

instead of combustion gases properties. This simplification will surely bring some differences in comparison to the case when the combustion gases were used, but the differences will be small because the combustion gases from the main gas turbine as well as combustion gases from the additional combustion chamber, Fig. 1, are dominantly composed of air with a small proportion of fuel [33, 34]. Therefore, this simplification will not have a major influence on the obtained exergy analysis results for any component as well as for the whole observed system, and at the same time will make performed calculations easier and faster.

4 Exergy analysis equations

In comparison to energy analysis which did not take into consideration parameters of the ambient in which analyzed system or a control volume operates [35, 36], exergy analysis takes into consideration parameters of the ambient (ambient pressure and ambient temperature) in which system or a control volume operates [37, 38]. Therefore, exergy analysis takes into consideration additional losses related to the ambient, which are not included in the energy analysis [39]. According to this fact, exergy analysis of any system or a component (control volume) present better operation and losses overview, so it can be a baseline for proper economy (exergo-economy) analysis [40-42].

4.1 Overall equations and balances valid for any system or a control volume

As defined in [43, 44], exergy analysis of any system or a control volume has a baseline in the second law of thermodynamics (second law analysis). Overall exergy balance equation, valid for any system or a control volume, can be written according to [45, 46] as:

$$\dot{X}_H + P_{IN} + \sum \dot{E}x_{IN} = P_{OUT} + \sum \dot{E}x_{OUT} + \dot{E}x_D \quad (1)$$

From Eq. 1 two variables should be defined by an additional equations. The first of these variables is \dot{X}_H - exergy transfer by heat at the temperature T , which is defined according to [47, 48] as:

$$\dot{X}_H = \sum \left(1 - \frac{T_0}{T}\right) \cdot \dot{Q} \quad (2)$$

The second variable from Eq. 1 which needs additional definition is $\dot{E}x$ - a total exergy flow of any fluid stream, which equation is, according to [49]:

$$\dot{E}x = \dot{m} \cdot \varepsilon \quad (3)$$

In Eq. 3, ε is specific exergy of any fluid stream which is calculated according to recommendations from [50], by using an equation:

$$\varepsilon = (h - h_0) - T_0 \cdot (s - s_0) \quad (4)$$

The exergy efficiency of any system or a control volume can be defined through general form as recommended in [51, 52], by an equation:

$$\eta_x = \frac{\text{cumulative exergy output}}{\text{cumulative exergy input}} \quad (5)$$

In standard operation of any system or a control volume, mass flow rate leakage of any fluid stream usually did not occur [53]. So, in standard operation, the mass flow rate balance [54] can also be applied:

$$\sum \dot{m}_{IN} = \sum \dot{m}_{OUT} \quad (6)$$

Presented overall exergy equations and balances will be a baseline for defining all exergy equations during the analysis of whole observed waste heat recovery CO₂ closed-cycle gas turbine system as well as for defining exergy analysis equations of each system component.

4.2 Equations for the exergy analysis of the observed CO₂ closed-cycle gas turbine system

Equations required for the exergy analysis of the whole observed system and for each system component are ar-

ranged in several tables in this sub-section. For each component, as well as for the whole observed system are defined equations for the calculation of exergy power input, exergy power output, exergy destruction (exergy power loss) and exergy efficiency, as a standard elements in any exergy analysis [55, 56].

Markings in all the equations presented in this sub-section related to each component are defined according to operating points from Fig. 1, while markings in all the equations presented in this sub-section related to the whole observed system are defined according to operating points from Fig. 2.

In Table 2 are presented exergy analysis equations of all heat exchangers from the observed waste heat recovery CO₂ closed-cycle gas turbine system. Equations for each heat exchanger are defined according to recommendations from the literature [57, 58].

Inside the observed waste heat recovery CO₂ closed-cycle gas turbine system exists two CO₂ gas turbines (T1 and T2) as well as two CO₂ compressors (Compr1 and Compr2). Produced mechanical power by each turbine, as well as used mechanical power by each compressor is an essential element in exergy analysis of each component. Therefore, the equations for the calculation of produced

Table 2 Exergy analysis equations of all heat exchangers from the observed waste heat recovery CO₂ closed-cycle gas turbine system

Component	Exergy power input	Eq.	Exergy power output	Eq.
H1	$\dot{E}x_{IN,H1} = \dot{E}x_1 - \dot{E}x_2$	(7)	$\dot{E}x_{OUT,H1} = \dot{E}x_{10} - \dot{E}x_9$	(13)
H2	$\dot{E}x_{IN,H2} = \dot{E}x_2 - \dot{E}x_3$	(8)	$\dot{E}x_{OUT,H2} = \dot{E}x_{20} - \dot{E}x_{19}$	(14)
HTR	$\dot{E}x_{IN,HTR} = \dot{E}x_{11} - \dot{E}x_{12}$	(9)	$\dot{E}x_{OUT,HTR} = \dot{E}x_9 - \dot{E}x_8$	(15)
LTR	$\dot{E}x_{IN,LTR} = \dot{E}x_{12} - \dot{E}x_{13}$	(10)	$\dot{E}x_{OUT,LTR} = \dot{E}x_7 - \dot{E}x_6$	(16)
IHX	$\dot{E}x_{IN,IHX} = \dot{E}x_{21} - \dot{E}x_{22}$	(11)	$\dot{E}x_{OUT,IHX} = \dot{E}x_{19} - \dot{E}x_{18}$	(17)
Cooler	$\dot{E}x_{IN,COOL} = \dot{E}x_{17} - \dot{E}x_4$	(12)	$\dot{E}x_{OUT,COOL} = \dot{E}x_{24} - \dot{E}x_{23}$	(18)
Component	Exergy destruction	Eq.	Exergy efficiency	Eq.
H1	$\dot{E}x_{D,H1} = \dot{E}x_{IN,H1} - \dot{E}x_{OUT,H1}$	(19)	$\eta_{x_{H1}} = \frac{\dot{E}x_{OUT,H1}}{\dot{E}x_{IN,H1}}$	(25)
H2	$\dot{E}x_{D,H2} = \dot{E}x_{IN,H2} - \dot{E}x_{OUT,H2}$	(20)	$\eta_{x_{H2}} = \frac{\dot{E}x_{OUT,H2}}{\dot{E}x_{IN,H2}}$	(26)
HTR	$\dot{E}x_{D,HTR} = \dot{E}x_{IN,HTR} - \dot{E}x_{OUT,HTR}$	(21)	$\eta_{x_{HTR}} = \frac{\dot{E}x_{OUT,HTR}}{\dot{E}x_{IN,HTR}}$	(27)
LTR	$\dot{E}x_{D,LTR} = \dot{E}x_{IN,LTR} - \dot{E}x_{OUT,LTR}$	(22)	$\eta_{x_{LTR}} = \frac{\dot{E}x_{OUT,LTR}}{\dot{E}x_{IN,LTR}}$	(28)
IHX	$\dot{E}x_{D,IHX} = \dot{E}x_{IN,IHX} - \dot{E}x_{OUT,IHX}$	(23)	$\eta_{x_{IHX}} = \frac{\dot{E}x_{OUT,IHX}}{\dot{E}x_{IN,IHX}}$	(29)
Cooler	$\dot{E}x_{D,COOL} = \dot{E}x_{IN,COOL} - \dot{E}x_{OUT,COOL}$	(24)	$\eta_{x_{COOL}} = \frac{\dot{E}x_{OUT,COOL}}{\dot{E}x_{IN,COOL}}$	(30)

Table 3 Equations for mechanical power calculation – produced (turbines), used (compressors) and useful power

Component	Mechanical power	Eq.
T1	$P_{T1} = \dot{m}_{10} \cdot (h_{10} - h_{11})$	(31)
T2	$P_{T2} = \dot{m}_{20} \cdot (h_{20} - h_{21})$	(32)
Compr1	$P_{Compr1} = \dot{m}_4 \cdot (h_5 - h_4)$	(33)
Compr2	$P_{Compr2} = \dot{m}_{14} \cdot (h_{15} - h_{14})$	(34)
Useful	$P_{Useful} = P_{T1} + P_{T2} - P_{Compr1} - P_{Compr2}$	(35)

Source: Authors

Table 4 Exergy analysis equations of all turbines and compressors from the observed waste heat recovery CO₂ closed-cycle gas turbine system

Component	Exergy power input	Eq.	Exergy power output	Eq.
T1	$\dot{E}x_{IN,T1} = \dot{E}x_{10}$	(36)	$\dot{E}x_{OUT,T1} = \dot{E}x_{11} + P_{T1}$	(40)
T2	$\dot{E}x_{IN,T2} = \dot{E}x_{20}$	(37)	$\dot{E}x_{OUT,T2} = \dot{E}x_{21} + P_{T2}$	(41)
Compr1	$\dot{E}x_{IN,Compr1} = \dot{E}x_4 + P_{Compr1}$	(38)	$\dot{E}x_{OUT,Compr1} = \dot{E}x_5$	(42)
Compr2	$\dot{E}x_{IN,Compr2} = \dot{E}x_{14} + P_{Compr2}$	(39)	$\dot{E}x_{OUT,Compr2} = \dot{E}x_{15}$	(43)
Component	Exergy destruction	Eq.	Exergy efficiency	Eq.
T1	$\dot{E}x_{D,T1} = \dot{E}x_{IN,T1} - \dot{E}x_{OUT,T1}$	(44)	$\eta_{xT1} = \frac{P_{T1}}{\dot{E}x_{10} - \dot{E}x_{11}}$	(48)
T2	$\dot{E}x_{D,T2} = \dot{E}x_{IN,T2} - \dot{E}x_{OUT,T2}$	(45)	$\eta_{xT2} = \frac{P_{T2}}{\dot{E}x_{20} - \dot{E}x_{21}}$	(49)
Compr1	$\dot{E}x_{D,Compr1} = \dot{E}x_{IN,Compr1} - \dot{E}x_{OUT,Compr1}$	(46)	$\eta_{xCompr1} = \frac{\dot{E}x_5 - \dot{E}x_4}{P_{Compr1}}$	(50)
Compr2	$\dot{E}x_{D,Compr2} = \dot{E}x_{IN,Compr2} - \dot{E}x_{OUT,Compr2}$	(47)	$\eta_{xCompr2} = \frac{\dot{E}x_{15} - \dot{E}x_{14}}{P_{Compr2}}$	(51)

Source: Authors

Table 5 Equations for the exergy analysis of the whole observed waste heat recovery CO₂ closed-cycle gas turbine system

---	Whole system	Eq.
Exergy power input	$\dot{E}x_{IN,WS} = \dot{E}x_1 + \dot{E}x_{23}$	(52)
Exergy power output	$\dot{E}x_{OUT,WS} = \dot{E}x_3 + \dot{E}x_{24} + P_{Useful}$	(53)
Exergy destruction	$\dot{E}x_{D,WS} = \dot{E}x_{IN,WS} - \dot{E}x_{OUT,WS}$	(54)
	$\dot{E}x_{D,WS} = \sum \dot{E}x_{D, \text{of all components}} = \dot{E}x_{D,H1} + \dot{E}x_{D,H2} + \dot{E}x_{D,HTR} + \dot{E}x_{D,LTR} + \dot{E}x_{D,IHX} + \dot{E}x_{D,COOL} + \dot{E}x_{D,T1} + \dot{E}x_{D,T2} + \dot{E}x_{D,Compr1} + \dot{E}x_{D,Compr2}$	(55)
Exergy efficiency	$\eta_{xWS} = \frac{P_{Useful}}{\dot{E}x_1 + \dot{E}x_{23} - \dot{E}x_3 - \dot{E}x_{24}}$	(56)

Source: Authors

and used mechanical power by each turbine or compressor are defined according to recommendations from [59] and presented in Table 3.

Equations for all exergy analysis parameters of each turbine and each compressor from the observed waste heat recovery CO₂ closed-cycle gas turbine system are presented in Table 4 and are obtained by using the instructions from the literature [60].

In Table 5 are presented all the required exergy analysis equations related to the whole observed waste heat recovery CO₂ closed-cycle gas turbine system (markings are related to operating points from Fig. 2). As for each component, in any equation from Table 5 related to the whole system, are followed recommendations from the literature [61, 62].

5 Results and discussion

Exergy power inputs and outputs of all heat exchangers from the observed waste heat recovery CO₂ closed-cycle gas turbine system are presented in Fig. 3. Exact values of each exergy power input and output for each heat exchanger are presented under the diagram in Fig. 3.

It should be highlighted that H1 has the highest exergy power input and output in comparison to other heat exchangers because it is the first heat exchanger to whom are delivered combustion gases from the main marine gas turbine and from the additional combustion chamber, Fig. 1. Heat exchanger H2 has a little lower exergy power input and output in comparison to H1, Fig. 3. However, from Fig. 3 can be concluded that heat exchangers in which heat is transferred from combustion gases to CO₂ have the highest exergy power inputs and outputs in the observed system.

Cooler, used for CO₂ cooling before its compression in Compr1 (CO₂ cooling is performed with water) has the

lowest exergy power input and output in comparison to all other heat exchangers in the observed system.

In this analysis, presentation of exergy power inputs and outputs for all heat exchangers from the analyzed waste heat recovery CO₂ closed-cycle gas turbine system is crucial, because the difference between exergy power input and output define exergy destruction (exergy power loss), while the ratio of exergy power output and input define exergy efficiency of each heat exchanger, Table 2.

Exergy destructions (exergy power losses) and exergy efficiencies of all heat exchangers in the observed waste heat recovery CO₂ closed-cycle gas turbine system are presented in Fig. 4.

Heat exchangers H1 and H2 in which the heat is transferred from combustion gases to CO₂ have the lowest exergy destructions equal to 498.74 kW for H1 and 683.61 kW for H2 in comparison to all other heat exchangers. Consequentially, H1 and H2 have the highest exergy efficiencies in comparison to all other heat exchangers (94.94% for H1 and 92.04% for H2). Heat exchangers in which hotter CO₂ transferred heat to colder CO₂ (HTR, LTR and IHX) have higher exergy destructions and consequentially lower exergy efficiencies in comparison to H1 and H2, Fig. 4. It is interesting to observe that HTR has higher exergy efficiency equal to 86.18% in comparison to LTR (80.68%), regardless of higher exergy destruction (823.32 kW for HTR and 747.90 kW for LTR). The highest exergy destruction in comparison to other heat exchangers from the observed system is detected in IHX and is equal to 1132.10 kW, Fig. 4.

Also, it should be noted that regardless of the highest exergy destruction, IHX did not have the lowest exergy efficiency when taking into account all heat exchangers from the observed system.




Fig. 3 Exergy power inputs and outputs of all heat exchangers from the observed waste heat recovery CO₂ closed-cycle gas turbine system




Fig. 4 Exergy destruction and exergy efficiency of all heat exchangers from the observed waste heat recovery CO₂ closed-cycle gas turbine system

Source: Authors

When taking into consideration all the heat exchangers from the analyzed waste heat recovery CO₂ closed-cycle gas turbine system, the lowest exergy efficiency is detected in Cooler and equal to 51.84%. The Cooler has exergy destruction lower than IHX, but higher in comparison to other heat exchangers from the observed system, so the Cooler exergy destruction cannot be the only reason for such low exergy efficiency. The main reason for low Cooler exergy efficiency is cooling water, which represents Cooler exergy power output, Table 2. Water in the Cooler has significantly lower exergy power in comparison to CO₂ (Table 1) what resulted with a low value of Cooler exergy efficiency.

In the analyzed waste heat recovery CO₂ closed-cycle gas turbine system, two CO₂ gas turbines (T1 and T2) are mechanical power producers, while two CO₂ compressors (Compr1 and Compr2) are mechanical power consumers. The difference in produced mechanical power by turbines and consumed mechanical power by compressors is delivered to an electrical generator for additional electrical power production. Without the observed waste heat recovery system, heat energy from combustion gases will be released to the atmosphere and will be completely lost.

Fig. 5 presents produced, used and useful mechanical power in the waste heat recovery CO₂ closed-cycle gas tur-




Fig. 5 Produced (turbines), used (compressors) and useful mechanical power from the observed waste heat recovery CO₂ closed-cycle gas turbine system

Source: Authors

bine system. Each mechanical power is calculated by using equations from Table 3.

From the viewpoint of gas turbines as the mechanical power producers, it can be concluded that the dominant mechanical power producer is T1, while the secondary gas turbine is T2 (T1 produces 8378.11 kW, while T2 produces 6738.43 kW of mechanical power), Fig. 5. This difference can be explained by using Table 1 – T1 operates with little lower CO₂ mass flow rate, but with significantly higher CO₂ temperature at the inlet in comparison to T2.

The dominant mechanical power consumer is Compr1 which consumes 3105.41 kW of mechanical power, while Compr2 consumes only 806.32 kW of mechanical power. This difference can be explained again by using Table 1 – Compr1 operates with significantly higher CO₂ mass flow rate in comparison to Compr2.

The difference in produced mechanical power (cumulative by both gas turbines) and in used mechanical power (cumulative by both compressors) is useful power, which for the observed system and according to CO₂ operating parameters from Table 1, equals 11204.80 kW. Useful mechanical power drives an electrical generator in the analyzed system.

Exergy power inputs and outputs for all turbines and compressors from the observed system are calculated by using equations from Table 4. Necessary part of turbines and compressors exergy power inputs and outputs are also produced or used mechanical power presented in Fig. 5. For each turbine and compressor from the observed system, exergy power inputs and outputs are presented in Fig. 6, while the exact values of each input and output are presented under the diagram of each component.

From Fig. 6 can be clearly seen that the highest exergy power inputs and outputs of all turbines and compressors

have T1, while the lowest exergy power inputs and outputs is observed for Compr2.

A comparison of both turbines (T1 and T2) shows that T1 has higher exergy power inputs and outputs, but the difference is not significant. A comparison of both compressors (Compr1 and Compr2) shows that Compr1 has significantly higher exergy power inputs and outputs, what can be explained with several times higher CO₂ mass flow rate through Compr1, Table 1. Also, it is interesting to observe that Compr1 has higher exergy power input and output in comparison to T2, Fig. 6 – the main reason of such occurrence is almost two times higher CO₂ mass flow rate through Compr1 than through T2, regardless of the fact that T2 operates with much higher CO₂ temperatures, Table 1.

Exergy destructions and exergy efficiencies of all turbines and compressors from the analyzed waste heat recovery CO₂ closed-cycle gas turbine system are calculated by using equations from Table 4 and presented in Fig. 7.

By observing turbines from the analyzed system, T2 has higher exergy destruction and consequentially lower exergy efficiency in comparison to T1 (exergy destructions of T1 and T2 are equal to 410.65 kW and 427.42 kW, while exergy efficiencies are equal to 95.33% and 94.04%, respectively). However, it should be highlighted that the differences in exergy destructions and in exergy efficiencies of both turbines are small.

Comparison of Compr1 and Compr2 shows that Compr1 has notably higher exergy destruction and consequentially notably lower exergy efficiency. Therefore the differences in exergy destruction and in exergy efficiency between observed compressors are much higher in comparison to the same differences between turbines. Compr1 has exergy destruction and exergy efficiency equal to




Fig. 6 Exergy power inputs and outputs of all turbines and compressors from the observed waste heat recovery CO₂ closed-cycle gas turbine system




Fig. 7 Exergy destructions and exergy efficiencies of all turbines and compressors from the observed waste heat recovery CO₂ closed-cycle gas turbine system

Source: Authors

538.46 kW and 82.66%, while the same parameters for Compr2 are 105.45 kW and 86.92%, respectively, Fig. 7.

Comparison of exergy efficiencies between mechanical power producers (turbines) and mechanical power consumers (compressors), Fig. 7, show that in the observed system both turbines have notably higher exergy efficiencies in comparison to any compressor.

Exergy analysis of the whole observed waste heat recovery CO₂ closed-cycle gas turbine system is performed according to the scheme presented in Fig. 2 and by using equations from Table 5. Obtained exergy analysis results of the whole observed system, by using operating parameters from Table 1, are presented in Table 6.

From Table 6 can clearly be seen that the whole observed waste heat recovery CO₂ closed-cycle gas turbine system has exergy destruction equal to 6270.73 kW, while the exergy efficiency is equal to 64.12%.

Obtained exergy efficiency of the whole observed system is higher in comparison to conventional closed-cycle gas turbines [63, 64], what proves that application of such waste heat recovery system on-board ships with the gas turbine as a main propulsion element will be beneficial for the additional electrical power production.

However, it should be highlighted that such system will also bring many disadvantages into the ship engine room. The whole system uses CO₂ as an operating medi-

um, what will require installing of additional CO₂ tanks and compressors for CO₂ delivery to the system and CO₂ removing from the system (useful produced mechanical power in such systems is regulated by change of operating medium mass flow rate). Such system will require additional space in the ship engine room. As the operating medium is high pressure and high temperature CO₂, it should be ensured a good sealing in all the places where CO₂ can exit from the system. Maintenance of such system is complex and will require additional time and effort of the ship crew. Regardless of all the disadvantages, the additional produced mechanical power can overcome all the disadvantages, especially in a long operation period.

Presented waste heat recovery system will surely increase the efficiency of the whole propulsion plant with the gas turbine as main propulsion element and will ensure competitiveness of such propulsion plant with other known marine propulsion systems.

Future research of the analyzed waste heat recovery CO₂ closed-cycle gas turbine system will be based on the application of AI (Artificial Intelligence) methods and processes already developed by our research team [65-68]. The intention will be to analyze and perform optimization of the system operating parameters (Table 1) with an aim to decrease the system exergy destruction and simultaneously to increase system exergy efficiency.

Table 6 Obtained exergy analysis parameters of the whole observed waste heat recovery CO₂ closed-cycle gas turbine system

Whole system	Exergy power input (kW)	Exergy power output (kW)	Exergy destruction (kW)	Exergy efficiency (%)
	23074.56	16803.83	6270.73	64.12

Source: Authors

6 Conclusions

In this paper is performed an exergy analysis of marine waste heat recovery CO₂ closed-cycle gas turbine system. The presented system operates by using combustion gases from the main marine gas turbine and from the additional combustion chamber (if required). It is performed analysis of each system component individually, as well as analysis of the whole observed system. It is detected components which operation can be improved. The main conclusions from the presented research are:

- **Heat exchangers:** Heat exchangers H1 and H2 in comparison to all other heat exchangers have the lowest exergy destructions equal to 498.74 kW for H1 and 683.61 kW for H2 and simultaneously the highest exergy efficiencies (94.94% for H1 and 92.04% for H2). Heat exchangers HTR, LTR and IHX have higher exergy destructions and consequentially lower exergy efficiencies in comparison to H1 and H2. The lowest exergy efficiency is detected in Cooler (51.84%) because cooling water has significantly lower exergy power in comparison to CO₂.
- **Turbines and Compressors:** The dominant mechanical power producer is T1, while the secondary gas turbine is T2 (T1 produces 8378.11 kW, while T2 produces 6738.43 kW of mechanical power). T2 has higher exergy destruction and lower exergy efficiency in comparison to T1 (exergy destructions of T1 and T2 are equal to 410.65 kW and 427.42 kW, while exergy efficiencies are equal to 95.33% and 94.04%, respectively). The dominant mechanical power consumer is Compr1 which consumes 3105.41 kW of mechanical power, while Compr2 consumes only 806.32 kW of mechanical power. Compr1 has notably higher exergy destruction and notably lower exergy efficiency in comparison to Compr2. Exergy destruction and exergy efficiency of Compr1 are equal to 538.46 kW and 82.66%, while the same parameters for Compr2 are 105.45 kW and 86.92%, respectively.
- **Whole waste heat recovery system:** The whole observed waste heat recovery system has exergy destruction equal to 6270.73 kW, while the exergy efficiency is 64.12%. Useful power produced by the whole system and used for electrical generator drive equals 11204.80 kW.

Obtained high exergy efficiency of the whole observed system proves its application on-board ships with the gas turbine as a main propulsion element, for the additional electrical power production.

Acknowledgment

This research has been supported by the Croatian Science Foundation under the project IP-2018-01-3739, CEEPUS network CIII-HR-0108, European Regional Development Fund under the grant KK.01.1.1.01.0009 (DATACROSS), project CEKOM under the grant KK.01.2.2.03.0004, CEI

project "COVIDAi" (305.6019-20), University of Rijeka scientific grant uniri-tehnic-18-275-1447 and University of Rijeka scientific grant uniri-tehnic-18-18-1146.

NOMENCLATURE	
<i>Latin Symbols:</i>	
\dot{E}_x	total exergy flow of fluid, kW
h	specific enthalpy, kJ/kg
\dot{m}	mass flow rate, kg/s
p	pressure, bar or kPa
P	mechanical power, kW
\dot{Q}	energy transfer by heat, kW
S	specific entropy, kJ/kg·K
T	temperature, °C or K
\dot{X}_H	exergy transfer by heat, kW
<i>Greek symbols:</i>	
ε	specific exergy, kJ/kg
η_x	exergy efficiency, -
<i>Subscripts:</i>	
0	base ambient state (dead state)
D	exergy destruction (exergy loss)
IN	inlet (input)
OUT	outlet (output)
WS	whole system
<i>Abbreviations:</i>	
Compr1	CO ₂ compressor 1
Compr2	CO ₂ compressor 2
COOL	water cooler
H1	combustion gases heater 1
H2	combustion gases heater 2
HTR	high temperature recuperator
IHX	intermediate heat exchanger
LTR	low temperature recuperator
T1	CO ₂ turbine 1
T2	CO ₂ turbine 2

References

- [1] Muše, A., Jurić, Z., Račić, N., & Radica, G. (2020). *Modelling, performance improvement and emission reduction of large two-stroke diesel engine using multi-zone combustion model*. Journal of Thermal Analysis and Calorimetry, 1-14. (doi:10.1007/s10973-020-09321-7)
- [2] Lamas Galdo, M. I., Castro-Santos, L., & Rodríguez Vidal, C. G. (2020). *Selection of an Appropriate Pre-Injection Pattern in a Marine Diesel Engine Through a Multiple-Criteria Decision Making Approach*. Applied Sciences, 10(7), 2482. (doi:10.3390/app10072482)

- [3] Huang, M., Gowdagiri, S., Cesari, X. M., & Oehlschlaeger, M. A. (2016). *Diesel engine CFD simulations: Influence of fuel variability on ignition delay*. Fuel, 181, 170-177. (doi:10.1016/j.fuel.2016.04.137)
- [4] Mrzljak, V., Medica, V., & Bukovac, O. (2016). *Volume agglomeration process in quasi-dimensional direct injection diesel engine numerical model*. Energy, 115, 658-667. (doi:10.1016/j.energy.2016.09.055)
- [5] Sartomo, A., Santoso, B., & Muraza, O. (2020). *Recent progress on mixing technology for water-emulsion fuel: A review*. Energy Conversion and Management, 213, 112817. (doi:10.1016/j.enconman.2020.112817)
- [6] Senčić, T., Mrzljak, V., Blecich, P., & Bonefačić, I. (2019). *2D CFD simulation of water injection strategies in a large marine engine*. Journal of Marine Science and Engineering, 7(9), 296. (doi:10.3390/jmse7090296)
- [7] Lamas Galdo, M. I., Castro-Santos, L., & Rodriguez Vidal, C. G. (2020). *Numerical analysis of NOx reduction using ammonia injection and comparison with water injection*. Journal of Marine Science and Engineering, 8(2), 109. (doi:10.3390/jmse8020109)
- [8] Koroglu, T., & Sogut, O. S. (2018). *Conventional and advanced exergy analyses of a marine steam power plant*. Energy, 163, 392-403. (doi:10.1016/j.energy.2018.08.119)
- [9] Mrzljak, V., & Poljak, I. (2019). *Energy Analysis of Main Propulsion Steam Turbine from Conventional LNG Carrier at Three Different Loads*. NAŠE MORE: znanstveno-stručni časopis za more i pomorstvo, 66(1), 10-18. (doi:10.17818/NM/2019/1.2)
- [10] Fernández, I. A., Gómez, M. R., Gómez, J. R., & Insua, Á. B. (2017). *Review of propulsion systems on LNG carriers*. Renewable and Sustainable Energy Reviews, 67, 1395-1411. (doi:10.1016/j.rser.2016.09.095)
- [11] Ammar, N. R. (2019). *Environmental and cost-effectiveness comparison of dual fuel propulsion options for emissions reduction onboard LNG carriers*. Brodogradnja: Teorija i praksa brodogradnje i pomorske tehnike, 70(3), 61-77. (doi:10.21278/brod70304)
- [12] Budiyanto, M. A., & Nawara, R. (2020). *The optimization of exergoenvironmental factors in the combined gas turbine cycle and carbon dioxide cascade to generate power in LNG tanker ship*. Energy Conversion and Management, 205, 112468. (doi:10.1016/j.enconman.2020.112468)
- [13] Lorencin, I., Anđelić, N., Mrzljak, V., & Car, Z. (2019). *Multi-layer Perceptron approach to Condition-Based Maintenance of Marine CODLAG Propulsion System Components*. Pomorstvo, 33(2), 181-190. (doi:10.31217/p.33.2.8)
- [14] Baressi Šegota, S., Lorencin, I., Musulin, J., Štifić, D., & Car, Z. (2020). *Frigate Speed Estimation Using CODLAG Propulsion System Parameters and Multilayer Perceptron*. NAŠE MORE: znanstveni časopis za more i pomorstvo, 67(2), 117-125. (doi:10.17818/NM/2020/2.4)
- [15] Wang, Z., Li, J., Fan, K., & Li, S. (2017). *The off-design performance simulation of marine gas turbine based on optimum scheduling of variable stator vanes*. Mathematical Problems in Engineering, 2017. (doi:10.1155/2017/2671251)
- [16] Gonca, G. (2017). *Exergetic and ecological performance analyses of a gas turbine system with two intercoolers and two re-heaters*. Energy, 124, 579-588. (doi:10.1016/j.energy.2017.02.096)
- [17] Ahn, J., Noh, Y., Park, S. H., Choi, B. I., & Chang, D. (2017). *Fuzzy-based failure mode and effect analysis (FMEA) of a hybrid molten carbonate fuel cell (MCFC) and gas turbine system for marine propulsion*. Journal of Power Sources, 364, 226-233. (doi:10.1016/j.jpowsour.2017.08.028)
- [18] Hou, S., Zhang, F., Yu, L., Cao, S., Zhou, Y., Wu, Y., & Hou, L. (2018). *Optimization of a combined cooling, heating and power system using CO₂ as main working fluid driven by gas turbine waste heat*. Energy Conversion and Management, 178, 235-249. (doi:10.1016/j.enconman.2018.09.072)
- [19] Alklaibi, A. M. (2017). *Utilization of exhaust gases heat from gas turbine with air bottoming combined cycle*. Energy, 133, 1108-1120. (doi:10.1016/j.energy.2017.04.086)
- [20] Lorencin, I., Anđelić, N., Mrzljak, V., & Car, Z. (2019). *Genetic Algorithm Approach to Design of Multi-Layer Perceptron for Combined Cycle Power Plant Electrical Power Output Estimation*. Energies, 12(22), 4352. (doi:10.3390/en12224352)
- [21] Duan, A., Zhihuang, Y., Duan, Y., & Wang, Q. (2020). *Heat exchanger simulation and recovery device design of waste heat boiler of gas turbine generator set on ocean platform*. Journal of Intelligent & Fuzzy Systems, 38(2), 1257-1263. (doi:10.3233/JIFS-179488)
- [22] Kim, J. S., Kim, D. Y., & Kim, Y. T. (2019). *Thermodynamic analysis of a dual loop cycle coupled with a marine gas turbine for waste heat recovery system using low global warming potential working fluids*. Journal of Mechanical Science and Technology, 33(7), 3531-3541. (doi:10.1007/s12206-019-0647-9)
- [23] Pan, P., Yuan, C., Sun, Y., Yan, X., Lu, M., & Bucknall, R. (2020). *Thermo-economic analysis and multi-objective optimization of S-CO₂ Brayton cycle waste heat recovery system for an ocean-going 9000 TEU container ship*. Energy Conversion and Management, 221, 113077. (doi:10.1016/j.enconman.2020.113077)
- [24] Kakac, S., Liu, H., & Pramuanjaroenkij, A. (2020). *Heat exchangers: selection, rating, and thermal design*. CRC press.
- [25] Annaratone, D. (2010). *Handbook for Heat exchangers and tube Banks design*. Springer Science & Business Media.
- [26] Kostyuk, A., & Frolov, V. (1988). *Steam and gas turbines*. Mir Publishers.
- [27] Hou, S., Wu, Y., Zhou, Y., & Yu, L. (2017). *Performance analysis of the combined supercritical CO₂ recompression and regenerative cycle used in waste heat recovery of marine gas turbine*. Energy Conversion and Management, 151, 73-85. (doi:10.1016/j.enconman.2017.08.082)
- [28] Lemmon, E. W., Huber, M. L., & McLinden, M. O. (2010). *NIST Standard Reference Database 23, Reference Fluid Thermodynamic and Transport Properties (REFPROP)*, version 9.0, National Institute of Standards and Technology. R1234yf. fld file dated December, 22, 2010.
- [29] Mrzljak, V., Poljak, I., & Mrakovčić, T. (2017). *Energy and exergy analysis of the turbo-generators and steam turbine for the main feed water pump drive on LNG carrier*. Energy conversion and management, 140, 307-323. (doi:10.1016/j.enconman.2017.03.007)
- [30] Medica-Viola, V., Mrzljak, V., Anđelić, N., & Jelić, M. (2020). *Analysis of Low-Power Steam Turbine With One Extraction for Marine Applications*. NAŠE MORE: znanstveni časopis za more i pomorstvo, 67(2), 87-95. (doi:10.17818/NM/2020/2.1)
- [31] Kopac, M., & Hilalci, A. (2007). *Effect of ambient temperature on the efficiency of the regenerative and reheat Çatalağzı power plant in Turkey*. Applied Thermal Engineering, 27(8-9), 1377-1385. (doi:10.1016/j.applthermaleng.2006.10.029)

- [32] Mrzljak, V., Blečić, P., Anđelić, N., & Lorencin, I. (2019). *Energy and Exergy Analyses of Forced Draft Fan for Marine Steam Propulsion System during Load Change*. Journal of Marine Science and Engineering, 7(11), 381. (doi:10.3390/jmse7110381)
- [33] Ibrahim, T. K., Basrawi, F., Awad, O. I., Abdullah, A. N., Najafi, G., Mamat, R., & Hagos, F. Y. (2017). *Thermal performance of gas turbine power plant based on exergy analysis*. Applied thermal engineering, 115, 977-985. (doi:10.1016/j.applthermaleng.2017.01.032)
- [34] Ji, N. K., Li, S. Y., Wang, Z. T., & Zhao, N. B. (2017). *Off-design behavior analysis and operating curve design of marine intercooled gas turbine*. Mathematical Problems in Engineering, 2017. (doi:10.1155/2017/8325040)
- [35] Medica-Viola, V., Baressi Šegota, S., Mrzljak, V., & Štifanić, D. (2020). *Comparison of conventional and heat balance based energy analyses of steam turbine*. Pomorstvo, 34(1), 74-85. (doi:10.31217/p.34.1.9)
- [36] Mrzljak, V., Prpić-Oršić, J., & Senčić, T. (2018). *Change in steam generators main and auxiliary energy flow streams during the load increase of LNG carrier steam propulsion system*. Pomorstvo, 32(1), 121-131. (doi:10.31217/p.32.1.15)
- [37] Elhelw, M., Al Dahma, K. S., & el Hamid Attia, A. (2019). *Utilizing exergy analysis in studying the performance of steam power plant at two different operation mode*. Applied Thermal Engineering, 150, 285-293. (doi:10.1016/j.applthermaleng.2019.01.003)
- [38] Dincer, I., & Rosen, M. A. (2012). *Exergy: energy, environment and sustainable development*. Newnes.
- [39] Mrzljak, V., Poljak, I., & Žarković, B. (2018). *Exergy analysis of steam pressure reduction valve in marine propulsion plant on conventional LNG carrier*. NAŠE MORE: znanstvenostručni časopis za more i pomorstvo, 65(1), 24-31. (doi:10.17818/NM/2018/1.4)
- [40] Noroozian, A., Mohammadi, A., Bidi, M., & Ahmadi, M. H. (2017). *Energy, exergy and economic analyses of a novel system to recover waste heat and water in steam power plants*. Energy conversion and management, 144, 351-360. (doi:10.1016/j.enconman.2017.04.067)
- [41] Uysal, C., Kurt, H., & Kwak, H. Y. (2017). *Exergetic and thermoeconomic analyses of a coal-fired power plant*. International Journal of Thermal Sciences, 117, 106-120. (doi:10.1016/j.ijthermalsci.2017.03.010)
- [42] Taheri, M. H., Mosaffa, A. H., & Farshi, L. G. (2017). *Energy, exergy and economic assessments of a novel integrated biomass based multigeneration energy system with hydrogen production and LNG regasification cycle*. Energy, 125, 162-177. (doi:10.1016/j.energy.2017.02.124)
- [43] Mrzljak, V., Poljak, I., & Medica-Viola, V. (2017). *Dual fuel consumption and efficiency of marine steam generators for the propulsion of LNG carrier*. Applied Thermal Engineering, 119, 331-346. (doi:10.1016/j.applthermaleng.2017.03.078)
- [44] Kanoğlu, M., Çengel, Y. A. & Dincer, I. (2012). *Efficiency Evaluation of Energy Systems*. Springer Briefs in Energy. (doi:10.1007/978-1-4614-2242-6)
- [45] Szargut, J. (2005). *Exergy method: technical and ecological applications* (Vol. 18). WIT press.
- [46] Baldi, F., Ahlgren, F., Nguyen, T. V., Thern, M., & Andersson, K. (2018). *Energy and exergy analysis of a cruise ship*. Energies, 11(10), 2508. (doi:10.3390/en1102508)
- [47] Mrzljak, V., Poljak, I., & Prpić-Oršić, J. (2019). *Exergy analysis of the main propulsion steam turbine from marine propulsion plant*. Brodogradnja: Teorija i praksa brodogradnje i pomorske tehnike, 70(1), 59-77. (doi:10.21278/brod70105)
- [48] Aljundi, I. H. (2009). *Energy and exergy analysis of a steam power plant in Jordan*. Applied thermal engineering, 29(2-3), 324-328. (doi:10.1016/j.applthermaleng.2008.02.029)
- [49] Lorencin, I., Anđelić, N., Mrzljak, V., & Car, Z. (2019). *Exergy analysis of marine steam turbine labyrinth (gland) seals*. Pomorstvo, 33(1), 76-83. (doi:10.31217/p.33.1.8)
- [50] Tan, H., Shan, S., Nie, Y., & Zhao, Q. (2018). *A new boil-off gas re-liquefaction system for LNG carriers based on dual mixed refrigerant cycle*. Cryogenics, 92, 84-92. (doi:10.1016/j.cryogenics.2018.04.009)
- [51] Zhao, Z., Su, S., Si, N., Hu, S., Wang, Y., Xu, J., ... & Xiang, J. (2017). *Exergy analysis of the turbine system in a 1000 MW double reheat ultra-supercritical power plant*. Energy, 119, 540-548. (doi:10.1016/j.energy.2016.12.072)
- [52] Mrzljak, V., Senčić, T., & Žarković, B. (2018). *Turbogenerator steam turbine variation in developed power: Analysis of exergy efficiency and exergy destruction change*. Modelling and Simulation in Engineering, 2018. (doi:10.1155/2018/2945325)
- [53] Moran, M. J., Shapiro, H. N., Boettner, D. D., & Bailey, M. B. (2010). *Fundamentals of engineering thermodynamics*. John Wiley & Sons.
- [54] Kocijel, L., Poljak, I., Mrzljak, V., & Car, Z. (2020). *Energy Loss Analysis at the Gland Seals of a Marine Turbo-Generator Steam Turbine*. Tehnički glasnik, 14(1), 19-26. (doi:10.31803/tg-20191031094436)
- [55] Eboh, F. C., Ahlström, P., & Richards, T. (2017). *Exergy analysis of solid fuel-fired heat and power plants: a review*. Energies, 10(2), 165. (doi:10.3390/en10020165)
- [56] Ogorure, O. J., Oko, C. O. C., Diemuodeke, E. O., & Owebor, K. (2018). *Energy, exergy, environmental and economic analysis of an agricultural waste-to-energy integrated multigeneration thermal power plant*. Energy conversion and management, 171, 222-240. (doi:10.1016/j.enconman.2018.05.093)
- [57] Erdem, H. H., Akkaya, A. V., Cetin, B., Dagdas, A., Sevilgen, S. H., Sahin, B., ... & Atas, S. (2009). *Comparative energetic and exergetic performance analyses for coal-fired thermal power plants in Turkey*. International Journal of Thermal Sciences, 48(11), 2179-2186. (doi:10.1016/j.ijthermalsci.2009.03.007)
- [58] Adibhatla, S., & Kaushik, S. C. (2014). *Energy and exergy analysis of a super critical thermal power plant at various load conditions under constant and pure sliding pressure operation*. Applied thermal engineering, 73(1), 51-65. (doi:10.1016/j.applthermaleng.2014.07.030)
- [59] Ahmadi, G. R., & Toghraie, D. (2016). *Energy and exergy analysis of Montazeri steam power plant in Iran*. Renewable and Sustainable Energy Reviews, 56, 454-463. (doi:10.1016/j.rser.2015.11.074)
- [60] Kumar, V., Pandya, B., & Matawala, V. (2019). *Thermodynamic studies and parametric effects on exergetic performance of a steam power plant*. International Journal of Ambient Energy, 40(1), 1-11. (doi:10.1080/01430750.2017.1354326)
- [61] Ray, T. K., Datta, A., Gupta, A., & Ganguly, R. (2010). *Exergy-based performance analysis for proper O&M decisions in a steam power plant*. Energy Conversion and Management, 51(6), 1333-1344. (doi:10.1016/j.enconman.2010.01.012)
- [62] Şöhret, Y., Açıkkalp, E., Hepbasli, A., & Karakoc, T. H. (2015). *Advanced exergy analysis of an aircraft gas turbine engine: splitting exergy destructions into parts*. Energy, 90, 1219-1228. (doi:10.1016/j.energy.2015.06.071)

- [63] Olumayegun, O., Wang, M., & Kelsall, G. (2016). *Closed-cycle gas turbine for power generation: A state-of-the-art review*. *Fuel*, 180, 694-717. (doi:10.1016/j.fuel.2016.04.074)
- [64] Zare, V. (2020). *Performance improvement of biomass-fueled closed cycle gas turbine via compressor inlet cooling using absorption refrigeration; thermoeconomic analysis and multi-objective optimization*. *Energy Conversion and Management*, 215, 112946. (doi:10.1016/j.enconman.2020.112946)
- [65] Lorencin, I., Anđelić, N., Mrzljak, V., & Car, Z. (2019). *Marine Objects Recognition Using Convolutional Neural Networks*. *NAŠE MORE: znanstveno-stručni časopis za more i pomorstvo*, 66(3), 112-119. (doi:10.17818/NM/2019/3.3)
- [66] Lorencin, I., Anđelić, N., Španjol, J., & Car, Z. (2020). *Using multi-layer perceptron with Laplacian edge detector for bladder cancer diagnosis*. *Artificial Intelligence in Medicine*, 102, 101746. (doi:10.1016/j.artmed.2019.101746)
- [67] Štifanić, D., Musulin, J., Miočević, A., Baressi Šegota, S., Šubić, R., & Car, Z. (2020). *Impact of COVID-19 on Forecasting Stock Prices: An Integration of Stationary Wavelet Transform and Bidirectional Long Short-Term Memory*. *Complexity*, 2020. (doi:10.1155/2020/1846926)
- [68] Car, Z., Baressi Šegota, S., Anđelić, N., Lorencin, I., & Mrzljak, V. (2020). *Modeling the Spread of COVID-19 Infection Using a Multilayer Perceptron*. *Computational and Mathematical Methods in Medicine*, 2020. (doi:10.1155/2020/5714714)